



R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197

Florida Board of Professional Engineers Registry License No. 9813

Product Evaluation Report

Report No.: FL-6336.2

Date: July 2, 2026

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	Cline Aluminum Doors, Inc. 112 32nd Ave. West Bradenton, FL 34205-8096 800.648.6736	Series 100BE Aluminum Door Outswing "Impact"

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. for Cline Aluminum Doors, Inc. based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

- This product has been evaluated and is in compliance with the 9th Edition (2026) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
- Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- When used in areas requiring wind borne debris protection this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E 1996.
- For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
- Site conditions that deviate from the details of drawing FL-6336.2 require further engineering analysis by a licensed engineer or registered architect.
- See drawing FL-6336.2 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|---|---|---|--|
| 1. Test Report No.
TEL 01920362
TEL 01920363
TEL 01920452
TEL 01901410
TEL 01901408
TEL 01903975 | Test Standard
ASTM E 330-02/E 331-00, E 1886-05/1996-05
ASTM E 330-02/E 331-00
ASTM E 330-02/E 331-00, E 1886-05/1996-05
ASTM E 330-02/E 331-00, E 1886-05/1996-09
ASTM E 330-02/E 331-00, E 1886-05/1996-09
ASTM E 330-14/E 331-00, E 1886-19/1996-20 | Testing Laboratory
Testing Evaluation Lab.
Testing Evaluation Lab.
Testing Evaluation Lab.
Testing Evaluation Lab.
Testing Evaluation Lab.
Testing Evaluation Lab. | Signed by
Vivian K. Wright
Vivian K. Wright
Vivian K. Wright
Vivian K. Wright
Vivian K. Wright
Vivian K. Wright |
| 2. Drawing No.
No. FL-6336.2 | Prepared by
RW Building Consultants, Inc. (#9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 3. Miami-Dade NOA No.
23-0717.30 | Materials Testing
SentryGlas® Interlayer | | |
| 4. Calculations
Anchoring
ASTM E 1300 Glass Load | Prepared by
RW Building Consultants, Inc. (#9813)
RW Building Consultants, Inc. (#9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 5. Quality Assurance
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Cline Aluminum Doors, Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | | | |
- Digitally signed by Lyndon F Schmidt
Date: 2026.07.21 15:10:14 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 7-21-26.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA