

May 18, 2024

Mike Wittlin  
Storm Supply Depot  
10039 Harbourtown Court,  
Boca Raton, FL 33498.

Re: Secure Door Product Approval No. FL6420

**ENGINEER'S EVALUATION REPORT, STATEMENT OF CODE COMPLIANCE  
and EQUIVALENCE of PRODUCT STANDARDS**

I have evaluated the above-referenced product and find it to conform to the applicable sections of the 2023 Florida Building Code (8<sup>th</sup> Edition) including, but not limited to Section 1709.5.2.1 "Sectional Garage Doors and Rolling Doors"

**Test Report Number:** CTLA 1630W

| Test Standard-Year | Test Description    | Product Performance  |      |
|--------------------|---------------------|----------------------|------|
| ASTM E330-02       | Uniform Static Load | Minimum 78% Recovery | PASS |

Your product was tested to ASTM E330-02. The 2023 Florida Building Code references ASTM E330/E330M-14(2021). I have compared both standards and find them equivalent. The differences between the two are minor editorial changes and have no bearing on product performance.

**Test Report Number:** CTLA 1630W-1


| Test Standard-Year | Test Description        | Product Performance  |      |
|--------------------|-------------------------|----------------------|------|
| TAS 202-94         | Uniform Structural Load | Minimum 83% Recovery | PASS |

Please do not hesitate to contact me if you have any questions or comments, or require further information.

Sincerely,

  
Emma T. Mellinger, P.E.  
FL PE# 50049  
May 18, 2024

Emma Mellinger  
2024.05.18 18:01:09  
-04'00'



This item has been digitally signed and sealed by  
Emma T. Mellinger, P.E. on the date adjacent to the  
seal. Printed copies of this document are not  
considered signed and sealed and the signature must  
be verified on any electronic copies.