

# WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97<sup>th</sup> Road N  
West Palm Beach, FL 33412  
Ph/Fx: (561) 225-1982

## PRODUCT EVALUATION

PRODUCT: S200 SERIES FIXED WOOD WINDOWS

MANUFACTURER: MQ WINDOW AND DOOR  
1855 GRIFFEN ROAD, SUITE A-274  
DANIA BEACH, FL 33412

To all concerned,

The MQ S200 Series Fixed Wood Window, manufactured by MQ Window and Door, has been tested per TAS 201, 202, and 203 by Hurricane Test Lab, Inc. with results shown in test reports G118-0202-05, G118-0705-05, , 0118-1215-03, and G118-0816-04.

### Technical Documentation:

1. Drawing "W06-12", signed and sealed by Scott Wolters, PE.
2. Test Reports listed above by Hurricane Test Lab, Inc. signed and sealed by Vinu Abraham, PE or Timothy Marshall, PE.
3. Supplemental calculations to support "W06-12", signed and sealed by Scott Wolters, PE.

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all the requirements of the 5<sup>th</sup> Edition (2014) Florida Building Code generally, and chapters 16, 23, and 24 specifically, including the HVHZ provisions.

Limitations: This window is approved for use inside and outside of the HVHZ. It is large and small impact resistant. Shutters are not required.

### Overall Dimensions:

|                          |              |
|--------------------------|--------------|
| Maximum Frame Width:     | 57 5/16 in.  |
| Maximum Frame Height:    | 57 3/4 in.   |
| Maximum Design Pressure: | +60/-70 psf. |

Glazing Options:

3/8" Monolithic Laminated

5/32" Annealed

0.090" PVB Interlayer\*

5/32" Annealed

3/8" Monolithic Laminated

5/32" Annealed

0.075" Saflex CP Interlayer\*\*

5/32" Annealed

1" Insulated Laminated

5/32" Annealed

0.090" PVB Interlayer\*

5/32" Annealed

7/16" Air Space

5/32" Annealed

1" Insulated Laminated

5/32" Annealed

0.075" Saflex CP

Interlayer\*\*

5/32" Annealed

3/8" Air Space

5/32" Annealed

\* The 0.090" PVB Interlayer is Saflex IIIG manufactured by Eastman Chemical, per NOA# 15-1201.11.

\*\* The 0.075" Saflex CP Interlayer is manufactured by Eastman Chemical per NOA# 14-0423.15.

If you have any questions or need more information concerning this approval please contact me.

Thank you,

  
Scott Wolters  
FL PE# 62354  
OCT 20 2016

