

Product Evaluation Report**Report No.: FL-9267.1****Date: October 11, 2023**

Product Category	Sub Category	Manufacturer	Product Name
Window	Casement	Brannen Millwork 3379 East Hwy. 46 Register, Georgia 30452 Phone 912-488-2397	European Vent Casement Window "Impact"

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for Brannen Millwork based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas outside the "HVHZ" requiring wind borne debris protection, this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E 1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of drawing FL-9267.1 require further engineering analysis by a licensed engineer or registered architect.
6. See drawing FL-9267.1 for size and design pressure limitations.

Supporting Documents:

- | | | |
|--|--|--|
| <p>1. Test Report No.
TEL 07-01020200
TEL 07-01020201
TEL 01023760
TEL 01023761</p> <p>2. Miami-Dade NOA
23-0717.30
23-0713.20</p> <p>3. Drawing No.
No. FL 9267.1</p> <p>4. Calculations
Anchoring
ASTM E 1300 Glass Load</p> <p>5. Quality Assurance
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Brannen Millwork is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.</p> | <p>Test Standard
AAMA/WDMA/CSA101/I.S.2/A440-05
ASTM E 1886/1996-02
AAMA/WDMA/CSA101/I.S.2/A440-17
ASTM E 1886-13a/1996-14a</p> <p>Materials
SentryGlas Interlayer
Saflex PVB Interlayer</p> <p>Prepared by
RW Building Consultants, Inc. (#9813)</p> <p>Prepared by
RW Building Consultants, Inc. (#9813)
RW Building Consultants, Inc. (#9813)</p> | <p>Testing Laboratory
Testing Evaluation Lab., Inc.
Testing Evaluation Lab., Inc.
Testing Evaluation Lab., Inc.
Testing Evaluation Lab., Inc.</p> <p>Signed by
Wendell W. Haney, P.E.
Wendell W. Haney, P.E.
Vivian K. Wright
Vivian K. Wright</p> <p>Signed & Sealed by
Lyndon F. Schmidt, P.E.</p> <p>Signed & Sealed by
Lyndon F. Schmidt, P.E.</p> |
|--|--|--|

Digitally signed by Lyndon F Schmidt
Date: 2023.10.11 14:05:07 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 10-11-23.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA