

Product Evaluation Report**Report No.: FL-9607.10****Date: December 13, 2023**

Product Category	Sub Category	Manufacturer	Product Name
Window	Single Hung	MGM Industries 287 Freehill Rd Hendersonville, TN 37075 Phone 800.476.5584	Series 6060 Extruded Vinyl Twin Single Hung Window w/ Transom & Nailing Fin "Non-Impact"

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for MGM Industries based on Rule Chapter No. 61G20-3, Method 1a of the State of Florida Product Approval, Department of Business & Professional Regulation.

R W Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product anchoring drawing has been developed in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ). See the Certification Agency Certificate for sizes, specifications and ratings.
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product is required to be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
4. Site conditions that deviate from the details of drawing FL-9607.10 require further engineering analysis by a licensed engineer or registered architect.
5. See drawing FL-9607.10 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|--|--|--|-----------------------------------|
| 1. Test Report No.
MGM-006-02-05 | Test Standard
AAMA/WDMA/CSA101/I.S.2/A440-11 | Testing Laboratory
PRI Const. Materials Tech. | Signed by
Jason Simmons |
| 2. Drawing No.
No. FL-9607.10 | Prepared by
RW Building Consultants, Inc. (#9813) | Signed & Sealed by
Lyndon F. Schmidt, P.E. | |
| 3. Calculations
Anchoring
ASTM E1300 Glass Load | Prepared by
RW Building Consultants, Inc. (#9813)
RW Building Consultants, Inc. (#9813) | Signed & Sealed by
Lyndon F. Schmidt, P.E. | |
| 4. Quality Assurance
Certificate of Participation issued by FGIA, certifying that MGM Industries is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | | | |

Digitally signed by
Lyndon F Schmidt
Date: 2023.12.13
16:53:18 -05'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 12-13-23.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA